



rfo-sfps-rajkot@gujarat.gov.in



**FORM B 13.3**  
**FIRE SAFETY CERTIFICATE RENEWAL (FSCR)**  
(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFORAJ/2024/00088327  
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFORAJ/2024/00088327/R1

Date: 19/10/2024

Building Occupancy/Category: Educational (non-residential)

To,

R Madhavan Unny  
PRAGPAR- MANDVI ROAD SAMAGHOGHA SAMAGHOGHA MUNDRA Mundra Kachchh 370415  
Fire Region: Rajkot RFO  
Mobile No: 9925150358 Email ID: opjvn.principal@gmail.com

This has reference to your Application No. **2024/00090938** dated 16/10/2024 for **Fire Safety Certificate Renewal (FSCR)** for the building/premise **SHRI O P JINDAL VIDYA NIKETAN, C.B.S.E.- AFFIL 430206 C/O JINDAL SAW LTD- IPU (name of the Building/ Project)**, as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number: R.S. NO. 369/1 PAIKI 1/P4
4. Village Name: MUNDRA
5. Name of Block(s): SHRI O P JINDAL VIDYA NIKETAN CBSE AFFIL 430206 CO JINDAL SAW LTD IPU

The building/premise was inspected on **19/10/2024** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **19/10/2024**
2. Six monthly inspection was done on **19/10/2024**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **19/10/2026** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



**Digitally Verified**

Digitally verified by: Kamlesh Matiya  
Fire Safety Officer - General (FSO-G)  
2021/000021

Date: 19/10/2024  
Time: 11:30 AM



FSCA/O/RFORAJ/2024/00088327/R1

*This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at [www.gujfiresafetycop.in](http://www.gujfiresafetycop.in).*

*Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.*